

HE/ 316 /EEWW (P.&R.)/MR

20 JUN 2019

Executive Engineer Water Works  
Planning & Research, Room # 33,  
3rd floor, 'B' Ward Municipal Office,  
121, Ramchandra Bhatt 'X' lane,  
Opp. J. J. Hospital, Byculla,  
Mumbai - 400 009.  
☎ 91 - 22 - 2377 8341.

To,

Mr. Vipul S. Rathod - Partner  
M/s Simplex Plast  
Plot no. 29, Survey 72/74,  
Dewan & Shah Udyog Nagar,  
Walliv phata, Vasai (E) - 401 208.

Subject : Application for MCGM's approval for ISI marked 'SIMPLEX' brand PE water storage tanks.

Reference : 1) Your letter dated 04.06.2019.

2) Scrutiny fee receipt no. 1003601923 Dt. 07.06.2019.

Sir,

This is in reference to your above cited proposal. In this connection I have to inform you that, MCGM has stopped maintaining approved product list for ISI marked products related to water supply. ISI marked water distribution products such as pipes & fittings, storage tanks etc. can now be used in MCGM Limits without any separate MCGM approval for the same.

Hence, being a BIS approved ISI marked product, separate MCGM approval is not necessary for marketing of ISI marked SIMPLEX brand water storage tanks (up to 5000 litres capacity, as per corresponding IS code) manufactured by M/s Simplex Plast, within MCGM Limits in compliance with following guide lines -

1. The rotational moulded polyethylene water storage tanks to be marketed within MCGM Limits shall possess valid BIS license.
2. Each tank to be used in MCGM Limit shall carry unique identification marks such as ISI mark, brand name, size and class of pipe, confirming standards and lot or batch number along-with year of manufacturing.
3. Tanks to be used in MCGM limits shall fulfil all the requirements as specified in IS: 12701 - Pt 1 & 2 - 1996 standards and their latest amendments.
4. Trained personnel shall be deputed to supervise the installation of each tank and to attend any complaints after installation of the same.
5. MCGM reserves the right to reject any ISI marked product without assigning any specific reason.
6. The company shall produce the in-house test reports or third party test reports or shall arrange for testing the said product at company's laboratory at its own cost as per the requirement of user department of MCGM, as and when requested to do so.
7. Company to fulfil any site specific requirement of the user department.

Thanking you.

Yours faithfully,

*WWR*  
*20-6/19*  
Executive Engineer Water Works  
(Planning & Research)